

**Addendum No. 3
February 4, 2019**

Project: **Beacom Hall 309 Renovation**
University of South Dakota
Vermillion, South Dakota
Project No: 0927.2815.18

Architect: Architecture Incorporated

Letting: **February 7, 2019
2:00 PM**
University of South Dakota
Purchasing Office
209 Slagle Hall
414 East Clark Street
Vermillion, South Dakota 57069

Scope of this Addendum:

To all bidders and all others to whom drawings and specifications have been issued by Architecture Incorporated, this Addendum forms a part of the Contract Documents. Acknowledge receipt of this addendum by listing its number and date in the bidder's Form of Proposal. Failure to do so may subject bidder to disqualification. This addendum modifies the drawings and specifications as follows:

GENERAL ITEMS:

- 1) SPECIFICATION SECTION 081416 – FLUSH WOOD DOORS
 - a) Delete Part 1.5.B – FSC accredited certification is not required for wood doors for this project.
- 2) SPECIFICATION SECTION 087100 – DOOR HARDWARE
 - a) Clarification – Part 2.4.E.1 – Rim Exit Devices for wood door shall be based on 99 Series.

MECHANICAL ITEMS:

- 1) DRAWING SHEET 8.12 – MECHANICAL DETAILS & SCHEDULES
 - a) Make the following changes to the Register Grilles and Diffuser Schedule:
 - i) MAX CFM =1200
 - ii) S.P.D. = 0.05”
 - iii) NC = 20

ELECTRICAL ITEMS:

- 1) SPECIFICATION SECTION 260533.13 – CONDUIT FOR ELECTRICAL SYSTEMS
 - a) Page 3, Section 2.2 E.3. Minimum size: Data/Voice conduits: “Conduit shall be 1 inch routed to accessible ceiling space with J-hooks to cable tray or rack” in lieu of “see voice and data system specification.”

2) DRAWING SHEET 9.12 – ELECTRICAL DETAILS & SCHEDULES

- a) Reference Lighting Fixture Schedule – For Type F4, F4E and F8 light fixtures: Provide LED package of 1200 lumens per foot.

GENERAL APPROVALS:

The following material or equipment furnished by the manufacturers listed, may be substituted as equivalent providing that each item, material, and piece of equipment conforms to the design and requirement of the specifications.

<u>SECTION</u>	<u>ITEM</u>	<u>MANUFACTURER</u>
26 5100	Interior Lighting Type F4	Nulite Lighting
26 5100	Interior Lighting Type F4E	Nulite Lighting
26 5100	Interior Lighting Type F8	Nulite Lighting
26 5100	Interior Lighting Type X	Sure-lites

END OF ADDENDUM